

Certificate of Compliance

Certificate: 1779452

Master Contract: 176579

Project: 1779452

Date Issued: March 24, 2006

Issued to: Herga Electric Limited
Northern Way
Suffolk, IP32 6NN Bury St. Edmunds
ENGLAND

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*

Issued by: G. Foulem



Authorized by: M.H.J. Hoendervangers



PRODUCTS

CLASS 3211 07 – INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

CLASS 3211 87 – INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - Certified to US Standards

Open Type pressure operated switch 6773-01, followed by U, followed by 1 or 2, followed by 01 through 29.
Rated 21A, 2HP, 250Vac, 1HP, 125Vac, 0-15 PSI

Notes:

- 1 Certified for use only where the suitability of the combination is determined by CSA International.
- 2 The model designation of these switches is completed by suffix letter and numbers, which indicate minor mechanical variations and microswitch specifications.
- 3 All ratings are max values. Lower values may be used.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards 177945 March 24, 2001 76571779452



Certificate: 1779452

Master Contract: 176579

Project: 1779452

Date: March 24, 2006

APPLICABLE REQUIREMENTS

CAN/CSA - C22.2 No. 0	General Requirements-Canadian Electrical Code, Part II
CAN/CSA - C22.2 No. 14	Industrial Control Equipment
US/UL Std. 508	Industrial Control Equipment



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1779452

Master Contract: 176579

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1779452	March 24, 2006	cCSAus original certification of switch types 6773-xx.