

Certificate of Compliance

Certificate: 1872877

Master Contract: 176579

Project: 2035567

Date Issued: October 15, 2008

Issued to: Herga Electric Ltd.
Nothern Way
Bury-St-Edmunds, Suffolk IP32 6NN
UNITED KINGDOM

The products listed below are eligible to bear the CSA Mark shown



Issued by: G. Foulem

Authorized by: M.H.J. Hoendervangers
Area Director Europe



PRODUCTS

CLASS 6241 10 – SWITCHES – Snap – Special Use

Air operated switches, Models 6871, SPDT; 6872, DPDT; 6873, SPDT and 6808 TPDT, 25A, 2HP max, 250V ac

Notes:

- 1 Certified for use only where the suitability of the combination is determined by CSA International.
- 2 The model designation of these switches is completed by suffix letter and numbers, which indicate minor mechanical variations and microswitch specifications, e.g. 6871-A00-U107
- 3 All ratings are max values. Lower values may be used.

APPLICABLE REQUIREMENTS

CAN/CSA - C22.2 No. 0-M91 (R2006)

General Requirements-Canadian Electrical Code, Part II

CAN/CSA - C22.2 No. 55-M1986 (R2003)

Special Use Switches